

Six Month Surveillance Summary

District: Central California Conference of 7th
Day Adventist

School: Valley View Jr. Academy

Date: August 8, 2011

Inspector: WRS PHILIPS

Building	HMR Number	Asbestos Material	Location	Condition Code/Comments
Administration Building	1	Carpet & glue blue grey square pattern	01 - Main Entry, 02 - Office, 03 - Staff Lounge, 04 - Custodial Closet, 05 - Classroom, 06 - Classroom	1, 4
Administration Building	2	Baseboard & glue 4" Dk Grey	01 - Main Entry, 02 - Office, 03 - Staff Lounge, 03A - Storage, 04 - Custodial Closet, 05 - Classroom, 06 - Classroom, 07 - Classroom, 11 - Classroom Hallway, 12 - Classroom, 13 - Corridor	1, 4
Administration Building	3	Drywall skip trowel texture	01 - Main Entry, 02 - Office, 03 - Staff Lounge, 03A - Storage, 03B - Staff Restroom, 04 - Custodial Closet, 05 - Classroom, 06 - Classroom, 07 - Classroom, 08 - Mens RR, 09 - Mechanical Room, 10 - Women RR, 11 - Classroom Hallway, 12 - Classroom, 13 - Corridor, 14 - Custodial Closet	1, 4
Administration Building	5	Sheet flooring & glue cream mosaic	03A - Storage, 07 - Classroom, 12 - Classroom	1, 4
Administration Building	6	Sheet flooring & glue grey mosaic	03B - Staff Restroom, 05 - Classroom, 06 - Classroom	1, 4
Administration Building	7	Fiber Re-inforced Panel & glue	03B - Staff Restroom, 14 - Custodial Closet	1, 4
Administration Building	8	Plumbers Sealant	03B - Staff Restroom	1, 4
Administration Building	9	Carpet & glue tan	04 - Custodial Closet, 07 - Classroom, 11 - Classroom Hallway, 12 - Classroom	1, 4
Administration Building	10	Whiteboard/Tackboard Glue	05 - Classroom, 06 - Classroom, 07 - Classroom, 12 - Classroom	1, 4
Administration Building	11	Sink Coating Silver	05 - Classroom, 06 - Classroom, 07 - Classroom, 12 - Classroom	1, 4
Administration Building	12	Sheet flooring & glue grey sand	08 - Mens RR, 13 - Corridor, 14 - Custodial Closet	1, 4
Administration Building	13	Ceramic Tile Grout - grey	08 - Mens RR	1, 4

Condition Codes

- General Condition: (1) Good (2) Damaged (3) Significantly Damaged (Damaged 25% or more)
Change in Condition: (4) No (5) Yes (if yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Misc: (11) Inaccessible, No surveillance data (12) Other (Explain under comments)

Date Printed: 9/18/2014

Six Month Surveillance Summary

District: Central California Conference of 7th
Day Adventist

School: Valley View Jr. Academy

Date: August 8, 2016

Inspector: Kels Phillips

Building	HMR Number	Asbestos Material	Location	Condition Code/Comments
Administration Building	14	Duct seam sealant - DK grey	09 - Mechanical Room	1, 4
Administration Building	15	Sheet flooring & glue - Tan sand	10 - Women RR	1, 4
Administration Building	16	Ceramic Tile Grout - Tan	10 - Women RR	1, 4
Administration Building	18	Acoustic Cling Tile Glue 12" Gouged PH	13 - Corridor	1, 4
Administration Building	22	Drywall unfinished w/ tape and joint	15 - Exterior Closet	1, 4
Gymnasium	19	Ceramic Tile Grout - Grey (G)	01 - Home EC, 01A - Custodial Closet, 01B - Dry Storage, 02 - NW Stairwell	1, 4
Gymnasium	20	Drywall skip trowel texture (G)	01 - Home EC, 01A - Custodial Closet, 02 - NW Stairwell, 07 - Boys Locker Room, 07A - North Storage, 07B - South Storage, 08 - Equipment Storage, 09 - Library, 09A - Storage, 10 - SW Stairwell, 11 - Classroom South, 12 - Classroom North, 14A - SW stage storage	1, 4
Gymnasium	23	Fiber Re-Inforced Panel & glue (G)	01A - Custodial Closet	1, 4
Gymnasium	24	Drywall smooth texture (G)	01B - Dry Storage, 03 - Women Restroom, 04 - Girls locker room hall, 05 - Girls Locker Room, 05A - North Storage, 05B - South Storage, 06 - Mens Restroom, 07 - Boys Locker Room	1, 5 holes in dry wall were fixed and room repainted.
Gymnasium	25	Baseboard & glue 4" Dk Grey (G)	03 - Women Restroom, 06 - Mens Restroom	1, 4
Gymnasium	26	Plaster sanded texture	03 - Women Restroom, 06 - Mens Restroom, 14A - SW stage storage, 15 - Stage	1, 4

Condition Codes

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (Damaged 25% or more)
 Change In Condition: (4) No (5) Yes (If yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Misc: (11) Inaccessible, No surveillance data (12) Other (Explain under comments)

Date Printed: 9/18/2014

Six Month Surveillance Summary

District: Central California Conference of 7th
Day Adventist

School: Valley View Jr. Academy

Date: August 8, 2016

Inspector: KRS Anderson

Building	HMR Number	Asbestos Material	Location	Condition Code/Comments
Gymnasium	27	Ceramic Tile Grout - White (G)	03 - Women Restroom, 06 - Mens Restroom	2, 4
Gymnasium	29	Carpet & glue brown	09 - Library, 13B - Office	1, 4
Gymnasium	30	Carpet & glue blue	09 - Library, 09A - Storage, 12 - Classroom North	1, 4
Gymnasium	31	Baseboard & glue 2" black	09 - Library	1, 4
Gymnasium	32	Plaster skip trowel texture	09 - Library	1, 4
Gymnasium	33	Carpet & glue blue/cream multi	11 - Classroom South	1, 4
Gymnasium	34	Whiteboard/Tackboard Glue (G)	11 - Classroom South, 12 - Classroom North	1, 4
Gymnasium	35	Carpet & glue blue/grey	13 - Classroom, 15 - Stage	1, 4
Gymnasium	36	Drywall Orange Peel Texture	13 - Classroom, 13A - Storage, 13B - Office	1, 4
Gymnasium	40	Sound board & glue	14 - Gymnasium	1, 4
Gymnasium	41	Carpet & glue brown/cream multi	15A - SW Stage level storage	1, 4
Gymnasium	42	Carpet & glue red	15C - Stage Storage	1, 4
Gymnasium	43	Drywall Sm Orange peel texture	15C - Stage Storage	1, 4
Storage	38	Carpet & glue brown (S)	Storage	1, 4
Storage	39	Drywall skip trowel texture (S)	Storage	1, 4

Condition Codes

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (Damaged 25% or more)
Change in Condition: (4) No (5) Yes (If yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Misc: (11) Inaccessible, No surveillance data (12) Other (Explain under comments)

Date Printed: 9/18/2014