

## Six Month Surveillance Summary

DISTRICT: Central California Conference of 7<sup>th</sup> Day Adventist

DATE: August 5, 2016

SCHOOL: Sierra View Junior Academy

INSPECTOR: Eliazib Cabrera

Building	HMR Number	Asbestos Material	Location	Condition Code/Comments
Administration Building	2	Baseboard & glue 4" black	01 - Classroom, 03 - Library	4
Administration Building	3	Drywall smooth texture	01 - Classroom, 03 - Library, 03A - Storage, 09 - Hallway, 09A - Upstairs Storage, 11 - Classroom, 11A - SE Storage room, 12 - Classroom, Attic	4
Administration Building	4	Tackboard/Whiteboard glues	01 - Classroom, 03 - Library, 11 - Classroom, 12 - Classroom	5 new white boards all classrooms
Administration Building	5	Sink coating	01 - Classroom	4
Administration Building	7	Floor tile & glue 12" cream oatmeal	01A - Storage Room, 01B - Storage Room	4
Administration Building	8	Baseboard & glue 4" white	01A - Storage Room, 01B - Storage Room	4
Administration Building	9	Drywall sanded texture	01A - Storage Room, 02 - Storage Room, 06 - Workroom, 08 - Principal's Office, 10 - Downstairs Furnace Room, 12A - SW Storage Room	4
Administration Building	10	Drywall skip towel texture	01B - Storage Room	4
Administration Building	11	Floor tile & glue 9" tan w/dk brwn stks	02 - Storage Room, 03A - Storage	4
Administration Building	12	Carpet & glue - grey	03 - Library	4
Administration Building	19	Floor tile & mastic (concealed)	06 - Workroom, 07 - Corridor, 08 - Principal's Office	4
Administration Building	20	Drywall unfinished	07 - Corridor	4
Administration Building	21	False ceiling panel 2x4 fiss PH	07 - Corridor	4
Administration Building	24	Carpet & pad green multi	09 - Hallway	4

## Six Month Surveillance Summary

DISTRICT: Central California Conference of 7<sup>th</sup> Day Adventist

DATE: August 5, 2016

SCHOOL: Sierra View Junior Academy

INSPECTOR: Eliazib Cabrera

Building	HMR Number	Asbestos Material	Location	Condition Code/Comments
Administration Building	25	Drywall Unfinished w/T&J	10 - Downstairs Furnace Room	4
Administration Building	76	Floor tile & mastic (concealed) #2	11D - Girls Restroom Foyer, 11E - Girls Restroom	4
Administration Building	900	Transite 12"	09A - Upstairs Storage, 10 - Downstairs Furnace Room	4
Building 002	4	Tackboard/Whiteboard glues	04 - Classroom West	5 new whiteboards
Building 002	5	Sink coating	04 - Classroom West	4
Building 002	26	Carpet & glue - grey (Bldg 002)	01 - Classroom East, 01A - Storage Room North, 01B - Storage Room South, 04 - Classroom West, 04A - Storage Room	01-4 01A-7 01B-7 04-4
Building 002	27	Baseboard & glue 4" black (002)	01 - Classroom East, 04 - Classroom West, 04A - Storage Room	04A-7 01-4 04-4
Building 002	28	Drywall - brushed texture (002)	01 - Classroom East, 01A - Storage Room North, 01B - Storage Room South, 02 - Work Room, 03 - Storage Room, 04 - Classroom West, 04A - Storage Room	01-4 01A-7 01B-7 02-7 03-7
Building 002	29	Sprayed on ceiling on drywall	01 - Classroom East, 01A - Storage Room North, 01B - Storage Room South, 02 - Work Room, 03 - Storage Room, 04 - Classroom West, 04A - Storage Room	01-4 01A-7 01B-7 02-7 03-7 04-4 04A-7
Building 002	31	Floor tile & glue 12" beige (002)	02A - Work Room Restroom	02A-7
Building 002	33	Floor tile & glue 12" green oatmeal	03 - Storage Room	7

## Six Month Surveillance Summary

DISTRICT: Central California Conference of 7<sup>th</sup> Day Adventist

DATE: August 5, 2016

SCHOOL: Sierra View Junior Academy

INSPECTOR: Eliazib Cabrera

Building	HMR Number	Asbestos Material	Location	Condition Code/Comments
Building 002	35	Drywall smooth texture (Mech002)	05 - Mechanical Room	05-7
Building 002	39	Shingled Roofing (002)	Exterior	4
Building 002	40	Vapor Barrier (002)	Exterior	4
Gymnasium Building	4	Tackboard/Whiteboard glues	01 - Music, 02 - Classroom, 16 - 2 <sup>nd</sup> Floor Classroom East, 18 - 2 <sup>nd</sup> Floor Classroom West	4
Gymnasium Building	5	Sink coating	07 - Snack Bar	4
Gymnasium Building	46	Carpet & glue grey (gym)	01 - Music, 17 - East Gym Storage Room #2, 19 - West Gym Storage Room #2	4
Gymnasium Building	47	Baseboard & glue 4" brown	01 - Music	4
Gymnasium Building	48	Drywall skip towell texture (gym)	01 - Music, 02 - Classroom, 03 - Hallway West, 05 - Storage Room West, 06 - Hallway East, 09 - Storage Room East, 11 - SW Stage Storage, 12 - SE Stage Storage, 16 - 2 <sup>nd</sup> Floor Classroom East, 17 - East Gym Storage Room #2, 18 - 2 <sup>nd</sup> Floor Classroom West, 19 - West Gym Storage Room #2	4
Gymnasium Building	49	Acoustic fiber board	01 - Music	4
Gymnasium Building	50	Baseboard & glue 4" black (gym)	02 - Classroom	4
Gymnasium Building	51	Ceiling tiles 14"x30" & glue	02 - Classroom, 10 - Gymnasium	4
Gymnasium Building	52	Ceramic tile & grout 12" grey	03 - Hallway West, 06 - Hallway East	4

## Six Month Surveillance Summary

DISTRICT: Central California Conference of 7<sup>th</sup> Day Adventist

DATE: August 5, 2016

SCHOOL: Sierra View Junior Academy

INSPECTOR: Eliazib Cabrera

Building	HMR Number	Asbestos Material	Location	Condition Code/Comments
Gymnasium Building	53	Drywall smooth texture (gym)	04 - Girls Restroom Foyer, 04A - Girls Restroom, 07 - Snack Bar, 08 - Boys Restroom Foyer, 08A - Boys Restroom, 14 - 2 <sup>nd</sup> Floor SW Stage Storage, 15 - 2 <sup>nd</sup> Floor SE Stage Storage	4
Gymnasium Building	54	Plumbers Sealant (gym)	04A - Girls Restroom, 08A - Boys Restroom	4
Gymnasium Building	56	Sheet flooring & glue Grey squares	07 - Snack Bar	4
Gymnasium Building	57	Baseboard & glue 6" Tan	07 - Snack Bar	4
Gymnasium Building	58	Sprayed on acoustic on drywall (G)	10 - Gymnasium, 13 - Stage	
Gymnasium Building	59	Carpet & glue blue (gym)	11 - SW Stage Storage, 13 - Stage, 16 - 2 <sup>nd</sup> Floor Classroom East, 18 - 2 <sup>nd</sup> Floor Classroom West	4
Gymnasium Building	60	Baseboard & glue 4" grey	16 - 2 <sup>nd</sup> Floor Classroom East, 18 - 2 <sup>nd</sup> Floor Classroom West	4
Gymnasium Building	61	False ceiling panel 2x4 fiss PH (G)	16 - 2 <sup>nd</sup> Floor Classroom East, 18 - 2 <sup>nd</sup> Floor Classroom West	4
MPR Building	62	Stucco (MPR)	Covered Walkway North, Covered Walkway West	CWN 6 GWN 4 New
MPR Building	63	Concrete block & mortar	01 - Girls' Lockerroom Hallway, 01A - Storage Room, 01B - Girls' Lockerroom/Shower/Restrooms, 02 - Ball Storage Room, 03 - Boys' Lockerroom Hallway, 03A - Storage Room, 03B - Boys' Lockerroom/Shower/Restrooms, Covered Walkway West	4
MPR Building	64	Floor tile & glue 12" white w/black spe	01 - Girls' Lockerroom Hallway, 01A - Storage Room, 03A - Storage Room	4

## Six Month Surveillance Summary

DISTRICT: Central California Conference of 7<sup>th</sup> Day Adventist

DATE: August 5, 2016

SCHOOL: Sierra View Junior Academy

INSPECTOR: Eliarib Cabrera

Building	HMR Number	Asbestos Material	Location	Condition Code/Comments
MPR Building	65	Baseboard & glue 4" lt grey (MPR)	01 - Girls' Lockerroom Hallway, 01A - Storage Room, 03 - Boys' Lockerroom Hallway, 03A - Storage Room	4
MPR Building	66	Drywall OP texture (MPR)	01 - Girls' Lockerroom Hallway, 01B - Girls' Lockerroom/Shower/Restrooms, 03 - Boys' Lockerroom Hallway, 03B - Boys' Lockerroom/Shower/Restrooms, 04 - Home Economics Classrooms, 04A - Storage Room North, 04B - Storage Room Center, 05 - Classroom, 06 - Classroom	4
MPR Building	67	Drywall Skip Trowel Texture (MPR)	01A - Storage Room, 02 - Ball Storage Room, 03A - Storage Room	4
MPR Building	68	Floor tile & glue 12" cream w/pink	02 - Ball Storage Room	4
MPR Building	69	Baseboard & glue 4" Yellow	02 - Ball Storage Room	4
MPR Building	70	Ceramic tile grout 2" lt grey	03B - Boys' Lockerroom/Shower/Restrooms	4
MPR Building	71	Ceramic tile grout - Dk grey	03B - Boys' Lockerroom/Shower/Restrooms	4
MPR Building	72	Sheet flooring & glue Orange squares	04 - Home Economics Classrooms, 04B - Storage Room Center	04-2
MPR Building	73	Carpet & glue grey (MPR)	04A - Storage Room North	4
MPR Building	74	Sprayed on ceiling on drywall (MPR)	04A - Storage Room North, 04B - Storage Room Center, 05 - Classroom	4
MPR Building	77	Carpet & glue blue (MPR)	05 - Classroom, 06 - Classroom	4
Portable Buildings	78	Carpet & glue - blue (PB)	01 - Classroom West, 02 - Classroom East	4
Portable Buildings	79	Wood Paneling & glue	01 - Classroom West, 02 - Classroom East	4

## Six Month Surveillance Summary

DISTRICT: Central California Conference of 7<sup>th</sup> Day Adventist

DATE: August 5, 2016

SCHOOL: Sierra View Junior Academy

INSPECTOR: Eliazab Cabrera

Building	HMR Number	Asbestos Material	Location	Condition Code/Comments
Portable Buildings	80	Fiberboard panels	01 - Classroom West, 02 - Classroom East	4

### Condition Codes

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (Damaged 25% or more)  
Change in Condition: (4) No (5) Yes (If yes, explain under comments)  
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restrict  
Misc: (11) Inaccessible, No surveillance data (12) Other (Explain under comments)